

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180628-E346418  
**Report Reference** E346418-20180627  
**Issue Date** 2018-JUNE-28

**Issued to:** SOCOMEC S A  
1 RTE DE WESTHOUSE  
BOITE POSTALE 10  
67235 BENFELD CEDEX FRANCE

**This is to certify that  
representative samples of**

SWITCHES, OPEN TYPE FOR USE IN PHOTOVOLTAIC  
SYSTEMS

Open type switches, manual for use in photovoltaic  
systems, INOSYS LBS-T Series 85P, rated 275A to 500A.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 98A, Outline OF for Open-Type Switches  
UL 98B, ENCLOSED AND DEAD-FRONT SWITCHES FOR  
USE IN PHOTOVOLTAIC SYSTEMS  
UL 98, Enclosed and Dead –Front Switches

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

